STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105587
Permit No.
Basin Ø49

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. no noi ~~07400~~

1. OWNER Richard Combs
MAILING ADDRESS 65 East 3850 South
Nibley, Ut 84321

ADDRESS AT WELL LOCATION 445 South 4th Street
Elko, Nevada
Subdivision Name: County: Elko

2. LOCATION ~~NW~~ SE ¼ SE ¼ Sec. 15 T 34N N/S R 55 E
PERMIT/WAIVER No. NDEP F-000046 (Issued by Water Resources) 001-422-012 Parcel No.

Latitude 40.49.641
Longitude 115.45.433
UTM E N
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition ☐ Deepen ☒ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Remove Vault				
Pull pipe		0	10.5	
Fill hole with Bentonite				
N 40.827944				
W 115.756307 NAD27				
Plugging of log 101382				

Date started: 9-Mar, 20 07
Date completed: 9-Mar, 20 07

7. Water Level
Static water level: 7.5 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX			

9. WELL CONSTRUCTION
Depth Drilled 12 Feet Depth Cased 10.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5	Inches	0	Feet	12	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.70	0.308	0	10.5

Perforations:
Type of perforation slotted
Size of perforation 0.020
From 5.5 feet to 10.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 0 to 10.5 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on site of contractor)
Date 3-17-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY