

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin 772

NOTICE OF INTENT NO. _____

1. OWNER Leroy Cambell ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 1873 3 miles east Interstate 80
Lovelock NV 89419 UP BUFFALO CAWYON
 2. LOCATION SE 1/4 SW 1/4 Sec. 1 T. 30 N. S. R. 33 E. Pershing County
 PERMIT NO. Domestic Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	20	20
Sand + Rock		20	100	80
Rock		100	140	40
Shale Rock		140	170	30
Hard Rock		170	190	10
Shale Rock		180	260	80
Sand		260	270	10
Shale Rock		270	340	70
clay		340	350	10
Clay + Gravel	yes	350	400	50

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1 8/8</u>	<u>+1</u>	<u>400</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 4
 From 360 feet to 400 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 80' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 80' feet to 140 feet

9. WATER LEVEL
 Static water level 192' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60 °F Quality Good

Date started May 15, 1999
 Date completed May 20, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12</u>		<u>6.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling Contractor
 Address 10760 Grass Valley Rd Contractor
Winn NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 071467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed Chris Klein
 By driller performing actual drilling on site or contractor
 Date May 20 1999

RECEIVED
 2006 AUG 23 AM 11:30
 STATE ENGINEERS OFFICE