COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105598
Permit No.
Basin 069

NOTICE OF INTENT NO. 58440

1. OWNER John Thomas
MAILING ADDRESS Star Route PO Box 129
Orovada, NV 89425

ADDRESS AT WELL LOCATION ~~3595~~ Highway 95
Orovada, NV 89425 3545

2. LOCATION ~~SW~~ SE ¼ NE ¼ Sec 15 T 38 N R 38 E Humboldt County

PERMIT NO. | Issued by Water Resources | 006-331-09 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Cobles & Corse sand		2	20	18
Clay		20	155	
Boulders & sand		155	160	
Clay		160	165	
Cobles & rock		165	167	
Clay w/ cobles		167	240	
Cobles		240	245	
Clay		245	280	
Fractured rock		280	290	
Clay		290	300	
Fractured w/ cobles		300	310	
Hard rock		310	319	
N 41°10.302				
H-117°40.935				
Elevation 4507				
N 41.171814				
W 117.681280 NAD27				

Date started June 22, 20 06
Date completed June 25, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		6

8. WELL CONSTRUCTION

Depth Drilled 319 Feet Depth Cased 319 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 5/8 Inches	0 Feet	319 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15	188	+1	319

Perforations:
Type perforation Factory cut
Size perforation 3/32x4
From 180 feet to 319 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 319 feet

9. WATER LEVEL
Static water level 225 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date July 17, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com