

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Log No. \_\_\_\_\_  
 Permit No. 070  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 33455

1. OWNER CHRIS BROWN ADDRESS AT WELL LOCATION 1070 E NATIONAL  
 MAILING ADDRESS P.O. Box 3083  
Winnemucca NV 89446  
 2. LOCATION NW 1/4 NW 1/4 Sec. 20 T 36 N 38 E Humboldt County  
 PERMIT NO. domestic 015 193 04 Albert Jones Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Topsoil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Cables (Sand)</u>		<u>5</u>	<u>40</u>	<u>35</u>
<u>Clay Red w/cables</u>		<u>40</u>	<u>80</u>	<u>40</u>
<u>Hard Rock</u>		<u>80</u>	<u>90</u>	<u>10</u>
<u>Sand / coarse gravel</u>		<u>90</u>	<u>120</u>	<u>30</u>

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 5/8 Inches From 0 Feet To 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1 3/8</u>	<u>71</u>	<u>120</u>

Perforations:  
 Type perforation Factory Cut  
 Size perforation 3/32 x 4  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 120 feet

9. WATER LEVEL  
 Static water level 20' feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature low °F Quality fair

Date started Aug. 6 1997  
 Date completed Aug. 8 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson Drilling Contractor  
 Address 10760 GRASS VALLEY ROAD Contractor  
Winnemucca NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date August 15 1997

RECEIVED  
 2006 AUG 23 AM 11:31  
 STATE ENGINEERS OFFICE