

TTBLW - MWIS

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105625
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61810

1. OWNER NAS FALLON ADDRESS AT WELL LOCATION 4755 Pasture Rd
MAILING ADDRESS 4755 Pasture Rd Fallon, NV. 89496
Fallon NV. 89496 Subdivision Name: NAS FALLON County: Churchill

2. LOCATION SW 1/4 Sec 24 T 18 S R 29 E Latitude 39.406885 UTM E 159841993 NAD 27
PERMIT/WAIVER No. IRP | 006-611-01 Longitude 118.675273 N 14819764.42 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other
4. PROPOSED USE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0'	6'	6'
SAND		6'	9'	3'
CLAY		9'	10'	1'
SAND		10'	14'	4'
CLAY		14'	20'	6'

9. WELL CONSTRUCTION
Depth Drilled 20 1/2 Feet Depth Cased 18 Feet
HOLE DIAMETER (BIT SIZE)
From 2 Inches To 0 Feet 18 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>5/16 .40</u>	<u>0</u>	<u>18</u>

Perforations:
Type of perforation manufactured slotted
Size of perforation .010
From 3 feet to 18 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes No
 Neat Cement 0 to 1 Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured
Gravel Pack: Yes No 2 1/2' to 18' Pumped Poured
Type: 2 1/2" Sand
Bentonite Chips: Yes No 1' to 2 1/2' Pumped Poured
Type: 3/8 CHIPS

Date started: 3.20 , 20 08
Date completed: 3.20 , 20 08

7. Water Level
Static water level: 7' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bregg Drilling Contractor
Address 950 Howe Rd Contractor
Martinez, CA 94553
Nevada contractor's license number
issued by the State Contractor's Board C23-0038113
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M-2328
Signed [Signature]
Date 3-20-08