STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105630
Permit No.
Basin 153

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61305

1. OWNER General Moly, Inc.
MAILING ADDRESS 2215 N. 5th Street
Elko, NV 89801

ADDRESS AT WELL LOCATION Mt. Hope
Hole #233P
Subdivision Name: County: Eureka

2. LOCATION NW ¼ SE ¼ Sec 7 T 22N N/S R 51 E
PERMIT/WAIVER No. M/O-1488
Issued by Water Resources
Parcel No.

Latitude
Longitude
UTM E 1877682 [x] NAD 27
N 14455385 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [x] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	70	70
Tuft		70	590	520

N 39.800989
W 116.154338 NAD27

Date started: 27-Feb , 20 08
Date completed: 28-Feb , 20 08

9. WELL CONSTRUCTION
Depth Drilled 590 Feet Depth Cased 588 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	590	Feet	0	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.156	0	20
2.375		Sch. 80	+2	588

Perforations:
Type of perforation Slotted
Size of perforation 0.02

From	Blank	588	feet to	568	feet
From	Screen	568	feet to	548	feet
From	Blank	548	feet to	+2	feet
From			feet to		feet
From			feet to		feet

Annular Seal: [x] Yes [ ] No

[x] Neat Cement	3	to	+3	[ ] Pumped	[x] Poured
[ ] Cement Grout		to		[ ] Pumped	[ ] Poured
[ ] Concrete Grout		to		[ ] Pumped	[ ] Poured
[x] ≥30% Bentonite Grout	543.5	to	20	[x] Pumped	[ ] Poured

Gravel Pack: [x] Yes [ ] No 588 to 543.5 [ ] Pumped [x] Poured
Type: #8 Sand and #60 Sand
Bentonite Chips: [x] Yes [ ] No 20 to 0 [ ] Pumped [x] Poured
Type: 3/8" kwik plug - coated pellets

7. Water Level
Static water level: 85 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5 gal Bucket	7.5	N/A	40 sec @590'

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc.
Contractor
Address PO Box 2748
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1819
Signed Gregory Secrist by MH
By driller performing actual drilling on site or contractor
Date 3/28/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY