STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105646
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61833

1. OWNER STINNETTE CONSTRUCTION
MAILING ADDRESS RENO, NV 89502

ADDRESS AT WELL LOCATION 4767 RANCHERIA FALLON, NV
Subdivision Name: County: Churchill

2. LOCATION SW ¼ NW ¼ Sec 16 T 19N N/S R 28 E
PERMIT/WAIVER No. 008-121-95 (Issued by Water Resources) Parcel No.

Latitude 39.51101°N
Longitude 118.85277°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COURSE SANDS		0	5	5
GRAY CLAY GUMMY		5	19	14
GRAY SANDY CLAY		19	110	91
GRAY CLAY SILTY		110	151	41
COURSE DG SANDS	XXX	151	200	49

N39.51111
W118.851791 NAD27

Date started: 08-Feb, 20 08
Date completed: 13-Feb, 20 08

7. Water Level
Static water level: 10 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	45	3 HRS

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	200 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 21	4.06	.316	20	200

Perforations:
Type of perforation SAW CUT
Size of perforation 3 X 3/32
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 200 ☐ Pumped ☒ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) CAPTIAL CITY WELL DRILLING AND PUMP SERVICE INC.
Address (Contractor) # 20 KIT KAT DRIVE
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed (By driller performing actual drilling on site or contractor) Michael L Hack
Date 2/15/08

(Rev 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

2008 MAR -4 PM 12:12