

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 105693  
Permit No. \_\_\_\_\_  
Basin 222

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 601.170 and NAC 600.040

NOTICE OF INVENT NO. 33698

1. OWNER CASABLANCA RESORTS LLC ADDRESS AT WELL LOCATION P-W-2  
MAILING ADDRESS 897 west Mesquite Blvd 811 - west Mesquite Blvd  
Mesquite NV 89027 Subdivision Name: \_\_\_\_\_ County: Clark  
2. LOCATION SE 1/4 NE 1/4 Sec 18 T 13 N R 71 E Latitude 36° 48' 27.1" NAD 83  
PERMIT NUMBER No. R-1405 | 001-18-602-008 Longitude 114° 05' 6.94" NAD 83

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Monitor  Municipal/Industrial  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  (AUGER) Other

6. LITHOLOGIC LOG

Material	Water Strain	From	To	Thick-ness
<u>Asphalt</u>	<u>WL 33'</u>	<u>0</u>	<u>3"</u>	
<u>Brown claye sand</u>		<u>3"</u>	<u>65'</u>	

9. WELL CONSTRUCTION

Depth Drilled 65 Feet Depth Cased 65 Feet

PIPE DIAMETERS (OUT SIDE)

From	To	Feet	Feet
<u>12</u> Inches	<u>0</u> Feet	<u>65</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>18.97</u>	<u>.280</u>	<u>0</u>	<u>65</u>

Perforations:

Type of perforation Factory slot  
Size of perforation .010

From	To	Feet	Feet
<u>30</u>	<u>65</u>		

Annular Seal:  Yes  No

Material	to	Feet	Feet
<input type="checkbox"/> Neat Cement			
<input type="checkbox"/> Cement Grout			
<input type="checkbox"/> Concrete Grout			
<input type="checkbox"/> ≥30% Bentonite Grout			

Gravel Pack:  Yes  No 28 to 65  Pumped  Poured  
Type: 10/20 Colorado silica sand

Bentonite Chips:  Yes  No 1 to 28  Pumped  Poured  
Type: 3/8 chips hydrated

**DCNR/DWR RECEIVED**  
 JUL 08 2008  
**LAS VEGAS OFFICE**

Date started: 6-16 , 20 08  
Date completed: 6-16 , 20 08

7. Water Level: 33' feet below land surface  
Artesian Flow: NA G.P.M. NA P.S.I.  
Water Temperature: NA °F  
Quality: good

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>2</u>	<u>N/A</u>	<u>.5</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration & Wells Contractor  
Address 570 Corinthian Way Contractor  
Las Vegas, NV 89030

Nevada contractor's license number issued by the State Contractor's Board 0012852  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057-T4

Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor

Date \_\_\_\_\_