

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 105710  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 694.010 and NAC 694.020

NOTICE OF INTENT NO. 33700

1. OWNER T-WHRLLC ADDRESS AT WELL LOCATION MW-3  
MAILING ADDRESS Plaza Hotel 1 main Street 900 East Fremont street  
Las Vegas NV 89101 Subdivision Name: \_\_\_\_\_ County: Clark  
2. LOCATION NW SE 34 T 20 N R 61 E Latitude 36° 10' 22.3" UTM E  NAD 83  
PERMITS/REVIEWS No. 139-34-612-059 Longitude 115° 08' 84.0"  NAD 83/08 81

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other  (AUGER)

6. LITHOLOGIC LOG

| Material                       | Water Strata | From | To   | Thick-ness |
|--------------------------------|--------------|------|------|------------|
| Asphalt                        |              | 0    | 6"   |            |
| fill sandy clay Lt brown       |              | 6"   | 3'   |            |
| Sandy clay Lt brown gray       |              | 3'   | 10.5 |            |
| Sandy clay Lt gray             |              | 10.5 | 15   |            |
| Sandy clay w/ Caliche moist    |              | 15   | 25   |            |
| Cl sandy clay w/ caliche white |              | 25   | 30   |            |

9. WELL CONSTRUCTION  
Depth Drilled 30 Feet Depth Cased 25 Feet  
HOLE DIAMETER (BY SIZE)  
From 8 Inches To 25 Feet  
Inches Feet  
Inches Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 4.5                | 10.74               | .237                    | 0           | 25        |

Perforations:  
Type of perforation Factory Blotted  
Size of perforation .020  
From 10 feet to 25 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 1 to 5  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: 8-12 silica sand  
Bentonite Chips:  Yes  No 5 to 8  Pumped  Poured  
Type: 3/8 chips

7. Water Level  
Static water level: 14.8 feet below land surface  
Artesian Flow: NA G.P.M. NA P.S.I.  
Water Temperature: NA °F  
Quality: good

8. WELL TEST DATA

| TEST METHOD: | <input checked="" type="checkbox"/> Bailor | <input type="checkbox"/> Pump | <input type="checkbox"/> Air Lift | G.P.M.   | Draw Down (Feet Below Static) | Time (Hours) |
|--------------|--|-------------------------------|-----------------------------------|----------|-------------------------------|--------------|
| Bailor       | <input checked="" type="checkbox"/>        | <input type="checkbox"/>      | <input type="checkbox"/>          | <u>1</u> | <u>24</u>                     | <u>.5</u>    |

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WDC Exploration & Wells Contractor  
Address 570 Corinthian Way Contractor  
Las Vegas, NV 89030  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractors Board 0012852  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057-T4  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 6-27-08

DCNR/DWR RECEIVED  
JUL 08 2008  
LAS VEGAS OFFICE