PLUGGED BY
NOI # 64713

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105754
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61016

1. OWNER CITY AND COUNTY OF CARSON CITY
MAILING ADDRESS 3505 BUTTI WAY
CARSON CITY , NV 89701

ADDRESS AT WELL LOCATION FUJI PARK URBAN FISHING POND
CLEAR CREEK RD, CARSON CITY , NV
Subdivision Name: County: Carson City

2. LOCATION SE ¼ SE ¼ Sec 31 T 15N N/S R 20 E
PERMIT/WAIVER No DEW-70 ~~WD70~~ NOT ASIGNED
Issued by Water Resources Parcel No.

Latitude 39.11459*n UTM E ☐ NAD 27
Longitude 119.77399*w N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other DEWATERING

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COIURSE DG SANDS		0	6	6
GRAY COLOR CLAY		6	10	4
COURSE GD SANDS		10	47	37
DE-WATERING WELL # 2				
N 39.114692				
W 119.772991 NAD27				

*See Plugging Log 109801

Date started: 04-Dec , 20 07
Date completed: 05-Dec , 20 07

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	26	24 HRS

9. WELL CONSTRUCTION
Depth Drilled 47 Feet Depth Cased 47 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
13 3/4	Inches	0	Feet	47	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.34	.188	+1.5	47

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3 X 3/32
From 22 feet to 42 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 1 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 6 to 47 ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 1 to 6 ☐ Pumped ☒ Poured
Type: 3/8 BAIROID CHIPS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on-site or contractor
Date 12/28/2007

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

2008 JAN -8 AM 11:36