

095 - 39° 05.930 N 119° 10.952 W

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY 105906

Log No.
Permit No.
Basin. 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60888

1. OWNER Jack Krask ADDRESS AT WELL LOCATION #3 FARRELL LANE
MAILING ADDRESS PO 293 YERINGTON NV 89447
ROSA MEND CALIF 93500
2. LOCATION NE 1/4 NE 1/4 Sec 9 T. 14 N. R. 25 E. Lyon Co County
PERMIT NO. 014-191-12 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Clay & Sand</u>		<u>94'</u>	<u>290'</u>	<u>196'</u>
<u>Tan color</u>				
<u>Mud</u>				
<u>Small Gravel</u>		<u>290'</u>	<u>313'</u>	<u>23'</u>
<u>Course Sand</u>				
<u>N 39.098930</u>				
<u>W 119.181551 N 1227</u>				

8. 313 WELL CONSTRUCTION 313
Depth Drilled 279' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)
From 6" To 3 1/8"
Inches 94' Feet 313' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5"</u>		<u>.188</u>	<u>84'</u>	<u>313'</u>

Perforations:
Type perforation Sawed
Size perforation 1/8" x 3"
From _____ feet to _____ feet
From 273' feet to 313' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal NOT KNOWN Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

Date started 3/13/08, 20
Date completed 3/15/08, 20

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	
	G.P.M.	Draw Down (Feet Below Static)	
	<u>506 gpm</u>	<u>3 1/2 ft</u>	<u>3 1/2 hr</u>

9. WATER LEVEL
Static water level 17' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jack Krask Contractor
Address PO Box 599 Contractor
Oliver Springs NV 89442
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Richard L. Seal
By driller performing actual drilling on site or contractor
Date 3/30/08