REPORT NO. A8.03

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 105950
PERMIT NO.
BASIN Ø84

NOTICE OF INTENT NO. 61166

1. OWNER Palomino Valley General Improvement District
MAILING ADDRESS 5105 Wayside Rd, Palomino Valley NV 89510

ADDRESS OF WELL 5105 Wayside Rd
Palomino Valley, NV

2. WELL LOCATION SW 1/4 SE 1/4 SEC. 33 T 23 R 21 E Washoe COUNTY

PERMIT NO 76042 PARCEL NO 77-350-02 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Compacted Clay & Gravel		0	5	5
Sands & Gravel		5	40	35
Sand, Gravel & Clay		40	90	50
Gravel With red Clay		90	205	115
Gray & Light Brown Rock		205	265	60
Broken Purple & Gray Rock	X	265	275	10
Gray & Purple Basalt		275	305	30
Broken Gray & Purple Basalt	X	305	315	10
Gray & Purple Basalt		315	335	20
Broken Gray & Purple Basalt	X	335	340	5
Gray & Purple Basalt		340	400	60
Broken Purple & Rust Color Basalt	X	400	432	32
Gray & Purple Basalt		432	581	151
Dark Purple Basalt		581	591	10
Broken Purple Basalt	X	591	593	2
Dark Purple Basalt		593	598	5

Notes : WGS-84 GPS: Latitude: N39 48.671 Longitude: W119 37.671
N 39.811295
W 119.626845 NAD27

Date Started 01/02/2008 Date Completed 01/24/2008

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
Air	100+		3

8. WELL CONSTRUCTION

Depth Drilled 598' Depth Cased 598'

HOLE DIAMETER (BIT SIZE)

13 Inches 0 Feet 50 Feet
10 5/8 Inches 50 Feet 598 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
8 5/8"	16.94	.188	+2'	598'

PERFORATIONS:
Type Perforation Dbl Perf Size Perforation 3/32 x 3
From 318 Feet to 378 Feet
From 398 Feet to 418 Feet
From 578 Feet to 598 Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [ ] Pumped [X] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 598 Feet

9. WATER LEVEL
Static Water Level 83 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cold F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2187

Signed Roger [signature]
By driller performing actual drilling on site or contractor

Dated Jan 31 2008