WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105971
Permit No.
Basin 044

NOTICE OF INTENT NO. 28693

1. OWNER Gateway Gold Corporation
MAILING ADDRESS 2681 E. Parleys Way Suite 204 Salt Lake City Ut 84109

ADDRESS AT WELL LOCATION Warm Springs Mine (from NOI, well # PLA-MW-1) RC 6-25-08

2. LOCATION ~~SE~~ ¼ ~~SE~~ ¼ Sec. 11 T. 42 N S R. 53 E. Elko County
PERMIT NO. M0-1480 Issued by Water Resources | NE NW Parcel No. | Lat. 41.557072 Long. -115.97874 WGS-84 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
alluvium	No	0	65	65
alluvium	Yes	65	110	45
Dolimitic Siltstone				
Grayish Black	no	110	140	30
Calcareous Siltstone	No	140	145	5
Grayish Black	No	145	155	10
Dolomitic Siltstone				
Dolomitic Siltstone		155	270	115
Grayish Black				
Some Fractures	205			
Below 205'	↓			
Blakish Gray		270	280	10
Dolomitic Siltstone	yes			
Grayish Black	yes	280	300	20
Dolomitic Siltstone				
Blackish Gray	yes	300	335	35
Dolomitic Siltstone				
Fractured				
	N41.557176			
	W115.97784	NAD27		

Date started Jan. 12, 2008
Date completed Jan. 16, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Primary use as Piezometer		

8. WELL CONSTRUCTION
Depth Drilled 335 Feet Depth Cased 335 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9½	Inches	0	Feet	135	Feet
6¼	Inches	135	Feet	335	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8		Sch 80 PVC	+1.66	175
6 in X 7 ft Steel Protector with Pad				

Perforations:
Type perforation Factory Slotted
Size perforation .050
From 175 feet to 335 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-170
Placement Method: ☑ Pumped ☐ Poured
Seal Type: 0-10 ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
10-170 Bentonite
Gravel Packed: ☑ Yes ☐ No
From 170 feet to 335 feet

9. WATER LEVEL
Static water level 116.1 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen Company (Contractor)
Address 4490 West 1707 South (Contractor)
Salt Lake City Ut. 84104
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1970
Signed William L. Franklin
By driller performing actual drilling on site or contractor
Date January 30, 2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627