

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 105989  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34567

1. OWNER Ewing Bords, Inc. ADDRESS AT WELL LOCATION 1300 N A St.  
MAILING ADDRESS 1200 N A St. Las Vegas, NV 89106-3915 Las Vegas, NV  
Subdivision Name: \_\_\_\_\_ County: Clark

2. LOCATION NW 1/4 NE 1/4 Sec 27 T 20 N R 61 E Latitude 36° 11' 06.1" UTM E  NAD 27  
PERMIT/WAIVER No. 139-27-501-007 Longitude 115° 08' 32.5" N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. AS-3

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Other Auger

6. LITHOLOGIC LOG AS-3

Material	Water Strata	From	To	Thick-ness
Fill		0	2	
sand/gravel		2	6	
caliche		6	8	
sandy clay		8	30	
Bentonite				
18 sand pack				
20				
Bentonite				
25 sand pack				
30				

Blank  
Grout  
Screen  
Blank  
Screen

9. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10	0	30

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	sch 40	0	30

Perforations:

Type of perforation Factory slot

Size of perforation .020

From 25 feet to 30 feet  
From 18 feet to 20 feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 17  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 24 to 30  Pumped  Poured  
Type: #3 17 30

Bentonite Chips:  Yes  No 20 to 24  Pumped  Poured  
Type: hole plug 17 27

Date started: June 16, 2008  
Date completed: June 10, 2008

7. Water Level  
Static water level: 20 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling Inc. Contractor  
Address 4255 W. Post Rd. Contractor  
Las Vegas, NV 89118  
Nevada contractor's license number 0054931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-15269

Signed \_\_\_\_\_  
By driller performing actual drilling on-site or contractor  
Date 6/25/08