

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 106 002  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34571

1. OWNER Aspen Highlands Holdings LLC ADDRESS AT WELL LOCATION 2417 S. Las Vegas Blvd.  
MAILING ADDRESS 143102 N. Frank Lloyd Wright Blvd #1340 Las Vegas, NV 89104  
Scottsdale, AZ 85260-8846 Subdivision Name: \_\_\_\_\_ County: Clark

2. LOCATION SW 1/4 SW 1/4 Sec 3 T 21 N 01R 01 E Latitude 38° 08' 37.7" UTM E  NAD 27  
PERMIT/WAIVER No. 1162-03-410-008 Longitude 115° 09' 22.6" N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. Well# MW-1

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0'	0.5'	0.5'
Fill		0.5'	2'	1.5'
Sand		2'	6.5'	4.5'
Caliche		6.5'	8.5'	2'
Sandy Clay		8.5'	12'	3.5'
Clay	116'	12'	25'	13'

9. WELL CONSTRUCTION  
Depth Drilled 25 Feet Depth Cased 25 Feet  
HOLE DIAMETER (BIT SIZE)  
From 8 Inches To 25 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>RVC</u>	<u>Sch 40</u>	<u>0</u>	<u>25</u>

Perforations:  
Type of perforation Factory Slot  
Size of perforation .070  
From 10 feet to 25 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 4'  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 8' to 25'  Pumped  Poured  
Type: #3  
Bentonite Chips:  Yes  No 4' to 8'  Pumped  Poured  
Type: hole aug

Date started: 6/17, 20 08  
Date completed: 6/17, 20 08

7. Water Level  
Static water level: 116 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Elite Drilling Inc. Contractor  
Address 4255 W. Post Rd. Contractor  
Las Vegas, NV 89118  
Nevada contractor's license number 0054931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869  
Signed \_\_\_\_\_  
By driller performing actual drilling on-site or contractor  
Date 6/19/08