



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34738

1. OWNER N DOT ADDRESS AT WELL LOCATION 6010 Blue Diamond Rd. LV. NV.
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NW 1/4 Sec. 24 T. 22 N/S R. 60 E CLARK County
 PERMIT NO. 61322 176-24-101-004 Parcel No. _____ Subdivision Name _____
issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Commercial Irrigation Test
 Municipal Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ABANDON Well</u>				
<u>Depth 560 FT</u>				
<u>6 5/8 Steel CASING PERFORATE BOTTOM TO 50 FT ABOVE WATER - 290 FT.</u>				
<u>Cement with Tremie Pipe - Bottom up to 290 ft. Neat Cement</u>				
<u>Cement Top 20 ft use A Cement plug at 20 ft.</u>				
<u>N 36° 01' 34.3</u> <u>mod 27</u>				
<u>W 115° 13' 23.4</u>				
<u>PLUGGING OF LOG # 50641</u>				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____

Inches _____ Feet _____ Feet

Inches _____ Feet _____ Feet

Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 06-21-08, 20 _____
 Date completed 06-25-08, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JUN 25 2008
 LAS VEGAS OFFICE

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor
 Address 5360 N. BONITA VISTA ST Contractor
LV. NV. 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V H Dimick
 By driller performing actual drilling on site or contractor
 Date 06-25-08