

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34737

1. OWNER Road & Highway Builders LLC ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7635 Dean Martin Dr. N Hot Gravel P.T
LV. NV. 89139
 2. LOCATION SE 1/4 SE 1/4 Sec. 09 T. 22 N/S R. 59 E. Clark County
 PERMIT NO. 2-1035 175-09-000-001
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Well
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	118	
Red Shale		118	224	
Cemented Gravel		224	258	
Reddish Sandstone		258	360	
Limestone & Water		360	510	
N 36° 02' 33.2				
W 115° 21' 49.9				
N 45° 27'				

8. WELL CONSTRUCTION
 Depth Drilled 510 Feet Depth Cased 510 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 360 Feet
9 7/8 Inches 360 Feet 510 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>72</u>	<u>510</u>

Perforations:
 Type perforation Factory
 Size perforation Screen
 From 460 feet to 500 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 178 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62.1 °F Quality _____

Date started 06-07-08, 20 _____
 Date completed 06-20-08, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista St
LV. NV. 89149 Contractor
 Nevada contractor's license number 10062
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 552
 Division of Water Resources, the on-site driller.
 Signed V. H. Dimick
 By driller performing actual drilling on site or contractor
 Date 06-23-08