

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34729
34736

1. OWNER John W. NIGER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 217
SEARCHLIGHT, Nev. 89046
 2. LOCATION NW 1/4 NW 1/4 Sec. 24 T. 28 N/S R. 63 E. CLARK County
 PERMIT NO. 243-24-000-002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Decomposed Granite</u>		<u>0</u>	<u>40</u>	
<u>GRANITE + WATER</u>		<u>40</u>	<u>45</u>	
<u>GRANITE + SAND</u>		<u>45</u>	<u>75</u>	
<u>RUNNY SAND</u>		<u>75</u>	<u>152</u>	
<u>CAVITY</u>		<u>152</u>	<u>158</u>	
<u>GRANITE</u>		<u>158</u>	<u>200</u>	

N 35.29-59.4
W 164.54-06.6 NAD 27

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches 0 Feet 50 Feet
10 Inches 50 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>		<u>1.88</u>	<u>1/2</u>	<u>7.5</u>
<u>8 5/8</u>	<u>16.94</u>	<u>1.88</u>	<u>+1</u>	<u>105</u>
<u>6 5/8</u>	<u>12.92</u>	<u>1.88</u>	<u>+2</u>	<u>200</u>

Perforations:
 Type perforation AIR PERFORATOR
 Size perforation 1/8 x four times
 From 152 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 7.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 32 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 F Quality _____

Date started 03-15-08, 20_____
 Date completed 04-15-08, 20_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 Draw Down (Per Below Static) Time (Hours) _____


10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. BONITA VISTA ST
LV, NV. 89149 Contractor
 Nevada contractor's license number 10062
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 552
 Division of Water Resources, the on-site driller
 Signed VH Dimick
 By driller performing actual drilling on site or contractor
 Date 06-15-08