WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106039
Permit No.
Basin 163

NOTICE OF INTENT NO. 33502

1. OWNER CLAY + MARLA TRUMAN
MAILING ADDRESS 8230 TRIBUTE LN.
LAS VEGAS NV. 89147-6117

ADDRESS AT WELL LOCATION SE CORNER OF TOPAZ AV. + LORENZO ST.
SANDY VALLEY NV 89019

2. LOCATION NE ¼ SE ¼ Sec. 16 T. 25 N/S R. 57 E. CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 219-16-701-010 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	10	10
CLAY		10	42	32
CLAY + GRAVEL		42	52	10
GRAVEL + SAND	W.B	52	60	8
CLAY + GRAVEL		60	80	20
GRAVEL + SAND	W.B	80	91	11
CEMENTED SAND + GRAVEL		91	102	11
GRAVEL + SAND	W.B	102	120	18
CLAY + GRAVEL		120	130	10
CALICHE	W.B	130	140	10

NAD 1983
35°-46-37B
115°-35-25B

Date started 6-21, 2006
Date completed 6-23, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Drawdown (Feet below static level)	Time (Hours)

DCNR/DWR RECEIVED JUL 01 2008 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.33	.316	0	140

Perforations:
Type perforation FACTORY SCREEN
Size perforation .020
From 140 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. Contractor
Address P.O. BOX 3505 PAHRUMP NV. 89041 Contractor
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-23-2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627