

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33505

1. OWNER ROBERT J + TERA ANN CONNOR ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4410 PEBBLE RD. TUSKEGEE ST. + GARNET AV. LAS VEGAS NV. 89139 SANDY VALLEY
 2. LOCATION SW 1/4 NW 1/4 Sec. 22 T. 24 N. R. 56 E. CLACK County _____
 PERMIT NO. 200-22-201-005 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	8	8
CLAY		8	25	17
CALICHE		25	30	5
CLAY + GRAVEL		30	58	28
CEMENTED GRAVEL		58	69	11
CLAY + GRAVEL		69	87	18
CALICHE		87	90	3
CLAY		90	106	16
GRAVEL	W.B	106	112	6
CLAY		112	120	8
CALICHE	W.B	120	132	12
CEMENTED GRAVEL / FRACTURE	W.B	132	140	8

N.A.D 83
 35° - 50' - 921"
 115° - 41' - 318"

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SCREEN
 Size perforation .020
 From 140 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 101 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. BOX 3505 Pahrump NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-8-2008

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 Date started 7-7, 2008
 Date completed 7-8, 2008

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
 JUL 21 2008
LAS VEGAS OFFICE