WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 1106076
Permit No.
Basin 108

NOTICE OF INTENT NO. 62065

1. OWNER Gilbert & Victoria Tortolani
MAILING ADDRESS 3339 Michael Drive
Marina, CA 93933

ADDRESS AT WELL LOCATION 3 Jeanie Drive
Yerington, NV 89447

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 12 (N/S) R. 25 E. Lyon County

PERMIT NO. Issued by Water Resources | 12-241-19 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil + Sand		0	11	11
Boulders Cobbles + Gravels		11	77	66
Clay + Gravels		77	88	11
Cobbles + Gravels		88	94	6
Clay + Gravels		94	137	43
Boulder / Rock		137	140	3
Clay + Gravels		140	160	20
GPS N38° 54.453 W119° 11.615	NGS84			
N 38,907644 W 119,192603 NAD27				

Date started April 21, 2008
Date completed April 24, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		6

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	60 Feet
9 7/8 Inches		60 Feet	160 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13#	.188	+1	20
6 5/8	PVC	Sch 40	20	160

Perforations:
Type perforation Sawed
Size perforation 1/8" x 3"
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 53 feet to 160 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc. (Contractor)
Address PO Box 599, Silver Springs, NV 89429 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 31841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2346

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-2-08

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627