WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106097
Permit No.
Basin 179

NOTICE OF INTENT NO. 59424

1. OWNER Javier Ciscar
MAILING ADDRESS POB 151233
Ely, NV 89315

ADDRESS AT WELL LOCATION 50 West 55th South St.
Ely, NV 89301
from NDI N 39° 14' 55.2" W 114° 51' 42.8" IVG584

2. LOCATION ~~NW~~ NE ¼ SE ¼ Sec. 15 T. 16 N ~~S~~ R. 63 E. White Pine County
PERMIT NO. Issued by Water Resources | APN 010-510-16 Parcel No. 1 | Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[XX] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sand & Gravel		3	10	7
Brown Clay		10	20	10
Clay & Small Gravel		20	26	6
Small Gravel		26	40	14
Brown Clay		40	55	15
Small Gravel		55	58	3
Brown Clay		58	65	7
Clay & Small Gravel		65	105	40
Sand		105	110	5
Brown Clay		110	135	25
Course Gravel (Water)	X	135	145	10
Clay w/ Gravel		145		
Stringers			185	40
Course Water Gravel	X	185	200	15
N 39.248732				
W 114.862414 NAD27				

Date started March 28, 20 08
Date completed April 2, 20 08

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75	78	1

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10-5/8	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	200

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 6 Rows
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [XX] Poured
Seal Type: [ ] Neat Cement [XX] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 112 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. Contractor
Address 557 Ely Ave. Contractor
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rick Lewis By Jerold D. Christiansen
By driller performing actual drilling on site or contractor
Date April 17, 2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627