STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106098
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61841

1. OWNER KENT BYERS RECEIVING TRUST
MAILING ADDRESS P.O. BOX 567
NE KIMBERLY, ID 83341

ADDRESS AT WELL LOCATION 1079 HELMAN
GARDNERVILLE, NV 89410
Subdivision Name: County: Douglas

2. LOCATION ~~SW~~ ¼ ~~SE~~ SW ¼ Sec 12 T 12N N/S R 20 E
PERMIT/WAIVER No. 1220-12-310-018
Issued by Water Resources Parcel No.

Latitude 38.91680°N
Longitude 119.68713°W
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
COURSE GRAVELS		3	26	23
COBBLES		36	82	46
BROWN CLAY SILTY SAND		82	168	86
BROWN CLAY		168	191	23
COURSE GRAVELS	XX	191	260	69

N 38.916894
W 119.686136 NAD27

Date started: 31-Mar, 20 08
Date completed: 02-Apr, 20 08

9. WELL CONSTRUCTION
Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	260' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr 21	4.06	.216	20	260

Perforations:
Type of perforation SAW CUT
Size of perforation 3 X 3/32
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 50 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 260 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 90 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
21	46	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address # 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael Hack (By driller performing actual drilling on site or contractor)
Date 04/15/2008

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY