STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106104
Permit No.
Basin 082

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60244

1. OWNER Todd Roberts
MAILING ADDRESS 3976 Kentwood
Reno, NV 89503

ADDRESS AT WELL LOCATION 270 Burkes Blvd/Reno, NV
~~Dwellings Dr~~
Subdivision Name: County: Washoe

2. LOCATION SW ¼ NE ¼ Sec 13 T 19N N/S R 18 E
PERMIT/WAIVER No. 039-131-31
Issued by Water Resources Parcel No.

Latitude N39'515854 UTM E ☐ NAD 27
Longitude 119'908088 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	63	63
gray clay		63	182	119
gravel		182	203	21
gray clay		203	245	42
hard rock		245	293	48
fractured rock		293	305	12

N39.515964
W 119.907080 NAD27

Date started: 2-4- , 20 08
Date completed: 8-Feb , 20 08

9. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	100	Feet
8 3/4	Inches	100	Feet	220	Feet
6 1/8	Inches	220	Feet	305	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	1.88	+2	220
5 9/16	10.7	1.88	200	305

Perforations:
Type of perforation factory mill slot
Size of perforation 3/32
From 180 feet to 200 feet
From 285 feet to 305 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 100 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 220 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 236 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	275	
10	300	
20	325	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc
Contractor
Address 4850 Joule St. Suite A5
Contractor
Reno, NV 89502
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
Signed
By driller performing actual drilling on site or contractor
Date 2/13/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY