STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106109
Permit No.
Basin 044

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62205

1. OWNER GAYLA PREECE & LARRY LEDNISKY
MAILING ADDRESS P. O. BOX 1814
ELKO, NV 89803

ADDRESS AT WELL LOCATION 7254 GOLDRUSH DRIVE
LOT 7, BLOCK 35
Subdivision Name: Meadow Valley Rancho #1 County: ELKO

2. LOCATION SW ¼ NW ¼ Sec 6 T 35N N/S R 57 E
PERMIT/WAIVER No. 030-035-007
Issued by Water Resources Parcel No.

Latitude 40.951650
Longitude 115.599727
UTM E 11T 0617856 [X] NAD 27
N 4534122 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	1	1
BROWN CLAY		1	20	19
GRAY CLAY		20	30	10
SAND & GRAVEL	X	30	100	70
COARSE GRAVEL	XX	100	120	20

Date started: 9-Jun, 20 08
Date completed: 10-Jun, 20 08

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1.5	120

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 2 to 50 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 120 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 50 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 15 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COOL °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed (By driller performing actual drilling on site or contractor)
Date 6/11/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY