

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 106116
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61733

1. OWNER Quadra-Robinson NV Mining **WCC-62R** ADDRESS AT WELL LOCATION Robinson Mine, 2 miles south of Ruth, NV
 MAILING ADDRESS P.O. Box 382 Ruth, NV 89319 **667958** County: White Pine
 2. LOCATION SW 1/4 NE 1/4 Sec 13 T16N R09E 06E 61E Latitude 39.255450 UTM E 617958 NAD 27
 PERMIT/WAIVER NO. NEV92105 **NA** Longitude 115.053453 N 4346722 NAD 83/WGS 84
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, Gravel		0'	20'	20'
Sand, Gravel		20'	55'	35'
Sandstone		55'	150'	95'
Sandstone		150'	320'	170'
<u>N 39.253451</u>				
<u>W 115.053453 NA 027</u>				
<u>N 39.255450</u>				
<u>W 115.053453 NA 027</u>				
PLUGGED BY				
UGL # 63671				
(T9)				
*See plugging Log # 109492				

9. WELL CONSTRUCTION

Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

From	To
14.750 Inches	0 Feet to 20 Feet
9.875 Inches	20 Feet to 320 Feet
Inches	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.750	28.04	.250	0	20
4.500	2.06	.237	+2	320

Perforations:

Type of perforation Slotted
 Size of perforation .020
 From 295 feet to 315 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0' to 50' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout 50' to 283' Pumped Poured
 Gravel Pack: Yes No 290' to 320' Pumped Poured
 Type: 1/4 x 1/8 SRI
 Bentonite Chips: Yes No 283' to 290' Pumped Poured
 Type: 3/8 Hole Plug

7. Water Level
 Static water level: 275 feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: _____ °F
 Quality: _____

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	Draw Down		Time (Hours)
G.P.M.	(Feet Below Static)		
<u>NA</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boart Longyear Drilling Services (CONTRACTOR)
 Address P.O. Box 5279 (CONTRACTOR)
Elko, NV 89802
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1959
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 16-Jun-08