STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 106124

Permit No.

Basin 083

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61970

1. OWNER Sean & Dawn Fuller
MAILING ADDRESS 165 Milke Way
Sparks NV. 89436

ADDRESS AT WELL LOCATION 2530 Flat Iron Rd.
Reno
Subdivision Name: County: Storey

2. LOCATION Sw¼SW¼ Sec28T18N/ R21E
PERMIT/WAIVER NO. 003-341-12
Issued by Water Resources Parcel. No.

Latitude 39.39308 UTM E ☐ NAD 27
Longitude 119.63597 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown volcanic rock		0	230	230
Gray Volcanic rock	x	230	330	100
N 39.393186				
W 119.634971 NAD27				
Storey Co. Permit				
#8118				

Date started: 6/5, 20 08
Date completed: 6/9, 20 08

9. WELL CONSTRUCTION

Depth Drilled 330 Feet Depth Cased 328 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
8 7/8 Inches	50 Feet	330 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	330

Perforations:
Type of perforation Machine cut
Size of perforation 3/32 x 3
From 248 feet to 328 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 328 ☐ Pumped ☒ Poured
Type: 1/4 x 1/8
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 250 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cool °F
Quality: Not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R Bruce MacKay
By driller performing actual drilling on site or contractor
Date 6/11/08

Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com