STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106133
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61835

1. OWNER JANE LOMMEL
MAILING ADDRESS P.O. BOX 1444
SE GARDNERVILLE , NV 89410

ADDRESS AT WELL LOCATION 1702 COYOTEE RD
GARDNERVILLE , NV 89410
Subdivision Name: County: Douglas

2. LOCATION ~~NE~~ ¼ ~~SW~~ ¼ Sec 26 T 13N N/S R 20 E
PERMIT/WAIVER No. NE 1320-26-001-012
Issued by Water Resources Parcel No.

Latitude 38.96457°N
Longitude 119.69740°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		140	163	23
COURSE SANDS		163	192	29
SMALL GRAVELS		192	240	48

N38.964669
W119.696405 NAD27

Date started: 03-Mar , 20 08
Date completed: 04-Mar , 20 08

9. WELL CONSTRUCTION
Depth Drilled 240 ~~100~~ Feet Depth Cased 240 ~~100~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	140	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	120	240

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3 X 3/32
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type: N/A
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 105 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COOLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING & PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature]
by driller performing actual drilling on site or contractor
Date 03/10/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

STATE ENG. OFFICE
2008 MAR 18 AM 11:00