STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106146
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60862

1. OWNER Gary & Rita Pederson
MAILING ADDRESS PO Box 341 Winnemucca, NV 89446

ADDRESS AT WELL LOCATION 7435 Allen Road
Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION SW¼NE¼ Sec13T35N/ R37E
PERMIT/WAIVER NO. 13-551-05
Issued by Water Resources Parcel. No.

Latitude N40°54.550 UTM E ☐ NAD 27
Longitude W117°45.908 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		135	145	10
Gravel / Sand		145	185	40
Cobbles/Gravel		185	200	15
Course gravel / Sand		200	230	30

N 40.909278
W 117.764165 NAD27

Date started: March 29, 20 08
Date completed: March 29, 20 08

9. WELL CONSTRUCTION
Depth Drilled 135-230 Feet Depth Cased 135-230 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/4 Inches	135 Feet	230 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	188	130	230

Perforations:
Type of perforation Factory Cut Slot
Size of perforation 3/32X4
From 190 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 105 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
Date April 1, 2008

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com