STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106183
Permit No.
Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61738

1. OWNER Quadra-Robinson NV Mining AGT-2P
MAILING ADDRESS P.O. Box 382
Ruth, NV 89319

ADDRESS AT WELL LOCATION Robinson Mine, 2 miles south of Ruth, NV
Subdivision Name: NA County: White Pine

2. LOCATION NE¼NE¼ Sec15T16N/ R62E
PERMIT/WAIVER NO. 62801 (Issued by Water Resources) NA (Parcel. No.)

Latitude 39.257967 UTM E 674859 ☒ NAD 27
Longitude 114.973408 N 4347153 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Material		0'	185'	185'
Clay		185'	305'	120'
Limestone		305'	345'	40'
Clay		345'	365'	20'
Monzanite		365'	380'	15'

Date started: 16-June, 20 08
Date completed: 23-June, 20 08

9. WELL CONSTRUCTION

Depth Drilled 380 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26.00 Inches	0 Feet	50 Feet
17.50 Inches	50 Feet	380 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20.00	104.13	.500	0	50
10.750	40.48	.375	+2	360

Perforations:
Type of perforation Wire Wrap
Size of perforation .125
From 180 feet to 240 feet
From 300 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0' to 50' ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50' to 380' ☐ Pumped ☒ Poured
Type: 1/2 x 3/8 SRI
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 34 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
67.0	NA	1.0

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Drilling Services (CONTRACTOR)
Address P.O. Box 5279 (CONTRACTOR)
Elko, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
Signed
By driller performing actual drilling on site or contractor
Date 24-Jun-08

RECEIVED 2008 JUN 27 AM 11:40 STATE ENGINEER'S OFFICE

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com