

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY **106197**

Log No. _____
 Permit No. _____
 Basin **179**

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **NO NPI**

1. OWNER **Quadra-Robinson NV Mining** **RP07-01** ADDRESS AT WELL LOCATION **Robinson Mine, 2 miles south of Ruth, NV**
 MAILING ADDRESS **P.O. Box 382**
Ruth, NV 89319 **Subdivision Name:** _____ **County:** **White Pine**

2. LOCATION **NW 1/4 Sec 15 T16N R62E** Latitude **37.59224** UTM E **674621** NAD 27
 PERMIT/WAIVER NO. **NW 17652** Longitude **114.975466** N **4346511** NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill Material		0'	20'	20'
Sandstone		20'	220'	200'
Calcareous Sandstone		220'	460'	240'
Marble		460'	595'	135'
Calcareous Sandstone		595'	610'	15'
Limestone		610'	640'	30'
Limestone		640'	665'	25'
Marble		665'	735'	70'
Peanut PD Chloritic		735'	780'	45'
Marble		780'	815'	35'
Marble Chloritic		815'	820'	5'
Marble		820'	845'	25'
Limestone		845'	960'	115'
Sandy Limestone		960'	1000'	40'
Limestone		1000'	1300'	300'

N 39.250422
W 114.975466 NAD27

Note:
 Transducer set @ **885'**

Date started: **05-Nov, 20 07**
 Date completed: **10-Nov, 20 07**

9. WELL CONSTRUCTION

Depth Drilled **1300** Feet Depth Cased **NA** Feet

HOLE DIAMETER (BIT SIZE)

From	To
14.750 Inches	0 Feet 40 Feet
6.750 Inches	40 Feet 925 Feet
6.250 Inches	925 Feet 1305 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.750	28.04	.250	+2	40

Perforations:

Type of perforation **NA**
 Size of perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0 to 20 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 >30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 870 to 900 Pumped Poured
 Type: **#8 SRI**

Bentonite Chips: Yes No 20 to 870 Pumped Poured
 Type: **3/8 Hole Plug 900 to 1300**

7. Water Level

Static water level: **687** feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: _____ °F
 Quality: _____

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Boart Longyear Drilling Services** (CONTRACTOR)
 Address **P.O. Box 5279** (CONTRACTOR)
Elko, NV 89802
 Nevada contractor's license number issued by the State Contractor's Board **0021976**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2308**

Signed _____
 By driller performing actual drilling on site or contractor
 Date **23-Apr-08**