STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106198
Permit No.
Basin 129

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **62652**

1. OWNER **Dave Jones**
MAILING ADDRESS **2805 Unionville Rd Unionville NV**

ADDRESS AT WELL LOCATION ~~2805 Unionville Road~~ **Unionville, NV 89418** 1271 Mohea Rd - Unionville
Subdivision Name: County: **Pershing**

2. LOCATION ~~SW¼NW¼~~ NE Sec31T30N/ R35E
PERMIT/WAIVER NO. **012-080-17** (Issued by Water Resources / Parcel. No.)

Latitude **N40°4334** Longitude **W118°09092**
UTM E ☐ N ☐ ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
Sand Cobles		0	10	10
Boulders		10	50	40
Cobles/gravel		50	70	20
Boulders		70	105	35
Loose gravel		105	120	15
Cobles/sand		120	130	10
Boulders		130	180	50
Gravel/cobles		180	202	22
Boulders		202	245	43
Gravel		245	250	5
Rock Mass		250	263	13
Boulders		263	270	7
Rock fracture		270	285	15
Hard Rock		285	300	15
Boulder	X	300	335	35
Gravel	X	335	350	15

N 40.933508
W 118.089949 NAD27

Date started: **May 27**, 20 **08**
Date completed: **June 3**, 20 **08**

9. *WELL CONSTRUCTION*
Depth Drilled **350** Feet Depth Cased **350** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	350 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	300
5	8	1.88	300	350

Perforations:
Type of perforation **Factory Cut**
Size of perforation **3/32 X 4**
From **280** feet to **300** feet
From **320** feet to **350** feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 350 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. *Water Level*
Static water level: **296** feet below land surface
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I
Water Temperature: **Cool** °F
Quality: **Good**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
Address **10760 S. Grass Valley Road** (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* **021467**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **2083**
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
Date **06/16/08**