

Log No. 106210
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60365

1. OWNER Jeri Hill ADDRESS AT WELL LOCATION 9270 Regil Road Silver Springs NV
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NE 25 T 17N N/S R 24 E LVA County _____
 PERMIT NO. 17-534-12 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
Large Sand		15	43	28
Small Gravel & Large Sand	+	43	105	62
Large Gravel	+	105	115	10
Associated size sand below	+	115		
Gravel			210	95

N 39.313571
 W 119.239343 NAD83

39.31347°N
 119.23933°W NAD83

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 210 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 210 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>0</u>	<u>10</u>
<u>6 5/8</u>		<u>SDR 21</u>	<u>10</u>	<u>210</u>

Perforations:
 Type perforation Grinder cut
 Size perforation 3/4 x 2 inch
 From 190 feet to 210 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 5.2 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 5.2 feet to 210 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow N/A G.P.M. 25+ P.S.I.
 Water temperature Cold °F Quality Clear

Date started 03-20-08, 2008
 Date completed 03-21-08, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>1.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2321
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-24-08