WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106235
Permit No.
Basin 021

NOTICE OF INTENT NO. 57227

1. OWNER Bright - Holland
MAILING ADDRESS
ADDRESS AT WELL LOCATION Washoe. Bokham Ranch

2. LOCATION NW 1/4 SE 1/4 Sec. 35 T 29 N/S R 19 E Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☒ Other ~~Cleaning~~ rescale

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ ~~Test~~
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ ~~Rotary~~ ☐ RVC
☒ ~~Air~~ ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Grey-Green Clay		1	170	169
Grey Silt		170	180	10
Grey-Clay		180	200	20
Grey-Sands		200	245	45

Wash over Top 10 feet
Add cement seal
Per engineer order.

N 40.339556
W 119.814267 NAD27

Date started Oct 24, 19 06
Date completed June 21 ~~Oct 24~~, 19 06

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	100	Feet
8	Inches	100	Feet	245	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	11.8	.188	~~+~~ 3	245

Perforations:
Type perforation machine slot
Size perforation .060
From feet to feet
From 220 feet to 245 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow >100 G.P.M. P.S.I.
Water temperature 80 °F Quality water test

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Contractor
Address Box 888 Contractor
Fallon.
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed By driller performing actual drilling on-site or contractor
Date Nov. 19. 06

USE ADDITIONAL SHEETS IF NECESSARY

LC DAM . 1400 9 2 2 2