STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116239
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61834

1. OWNER LARRY HAWKINS
MAILING ADDRESS P.O. BOX 958
NE CARSON CITY, NV 89706

ADDRESS AT WELL LOCATION 520 DUCK HILL RD
CARSON CITY, NV 89706
Subdivision Name:
County: ~~Carson City~~ Washoe

2. LOCATION NW ¼ SW ¼ Sec 36 T 16N N/S R 19 E
PERMIT/WAIVER No. 055-270-08
Issued by Water Resources
Parcel No.

Latitude 39.20802*N
Longitude 119.80177*W
UTM E
N
☐ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG SANDS		0	6	6
COURSE DG SANDS		6	119	113
BROWN DG CLAY SILTY		119	203	84
HARD GRANITE		203	298	95
DG SANDS		298	309	11
FRACTURED DG SANDS	XXX	309	360	51

N39.208124
W119.600769 NAD27

Date started: 18-Feb, 20 08
Date completed: 28-Feb, 20 08

9. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	360	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 SDR	4.06	.216	20 ~~230~~	360

Perforations:
Type of perforation SAW CUT
Size of perforation 3 X 3/32
From 320 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 100 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 360 ☐ Pumped ☐ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☐ No X to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 160 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	65	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING & PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed
By driller performing actual drilling on site or contractor
Date 03/15/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEER'S OFFICE
2008 MAR 18 AM 11:00
RECEIVED