WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10621
Permit No.
Basin 155A

NOTICE OF INTENT NO. 59425

1. OWNER Dave Woolfolk
MAILING ADDRESS 2865 Hwy. 20
Harper, OR 97906

ADDRESS AT WELL LOCATION Approx. 4 miles NW of Fish Creek Ranch

2. LOCATION SE ¼ NW ¼ Sec. 29 T 17 N/S R 53 E Eureka County
PERMIT NO. cert 2761 per 10908 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Cemented Sand & Gravel		2	60	58
Brown Clay		60	68	8
Cemented Sand & Gravel		68	100	32
Brown Clay w/ Gravel Stringers		100	130	30
Cemented Gravel & Sand		130	155	25
Course Gravel	X	155	165	10
Clay & Gravel		165	195	30
Clay w/ Course Gravel Stringers	X	195	220	25

N39.318353
W116.036574 NAD27

WGS 84
Lat. N 39° 19'05.8"
Long. W 116° 02' 14.9"
Elevation 6,027

Date started March 21, 2008
Date complated March 26, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	45	1 1/2

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10-5/8	0	220

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	220

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 6 Rows
From 120 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Ave. (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rick Lewis By Jerold D. Christiansen (By driller performing actual drilling on site or contractor)
Date April 3, 2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627