

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59425

1. OWNER Dave Woolfolk ADDRESS AT WELL LOCATION Approx. 4 miles NW of Fish Creek Ranch
 MAILING ADDRESS 2864 Hwy. 20 Harper, OR 97906
 2. LOCATION SE 1/4 NW 1/4 Sec. 29 T. 17 N. R. 53 E. Eureka County
 PERMIT NO. cert 2761 per 10908 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
(Copy of original log enclosed)				
Rig was set over well, blockage was encountered @ 130', wood & aluminum was drilled out to 160'. Steel was encountered @ 160' and was unable to remove steel from hole. No water was encountered in hole. Hole was filled w/ cement grout from 160' back to 3' below surface where casing was cut off.				
<u>N39.318353</u>				
<u>W116.036574 NAD27</u>				
<u>Plugging of log #215</u>				

8. WELL CONSTRUCTION
 Depth Drilled 172 Feet Depth Cased 171.2 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 Inches To 0 Feet 172 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8-5/8</u>	<u>40</u>	<u>0.425</u>	<u>0</u>	<u>171.2</u>

Perforations:
 Type perforation Unknown
 Size perforation 3/16 x 2
 From 101 feet to 171 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started March 26, 2008
 Date completed March 26, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>N/A</u>			

9. WATER LEVEL
 Static water level Dry feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Ave. Contractor
Ely, NV 89301
 Nevada contractor's license number 14790 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1793 Division of Water Resources, the on-site driller
 Signed Rich Lewis By Jerroll D. Christiansen
 By driller performing actual drilling on site or contractor
 Date April 3, 2008