WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106244
Permit No.
Basin 162

NOTICE OF INTENT NO. 32690

1. OWNER PAHRUMP UITITLITES
MAILING ADDRESS 6591 S JANE AVE
PAHRUMP, NV

ADDRESS AT WELL LOCATION 6591 S JANE AVE.

2. LOCATION SW 1/4 NE 1/4 Sec. 17 T 21S N/S R 54E E NYE County
PERMIT NO. M/0 553-A (Issued by Water Resources) 45-171-72 (Parcel No.) OLD HOME RANCH (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| EXISTING 75FT | | | | |
| CLAY | | 75 | 87 | 12 |
| CALICHE | | 87 | 95 | 8 |
| CLAY | | 95 | 100 | 5 |
| WGS84 | | | | |
| N 36 DEGREES 07.612 | | | | |
| W 115 DEGREES 55.835 | | | | |

DCNR/DWR
RECEIVED
JUL 23 2008
LAS VEGAS OFFICE

Date started 7/15/2008 , 19__
Date completed 7/15/2008 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 6.5 | Inches | 75 | Feet | 100 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 3/8 | SECH 80 PV | | -3 | 100 |
| | | | | |

Perforations:
Type perforation screen
Size perforation .020
From 75 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 70
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 70 feet to 100 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 7/15/2008

USE ADDITIONAL SHEETS IF NECESSARY