

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY
 0038181
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 106321
 Permit No. _____
 Basin 212

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33879

1. OWNER Elden Equity Fund 17 LLC ADDRESS AT WELL LOCATION 2401 N. Rancho DR
 MAILING ADDRESS 15206 Ventura Blvd #306 LAS VEGAS NV 89130
SHERMAN OAKS, CA 91463
 2. LOCATION SE 1/4 SW 1/4 Sec 18 T. 20 N. R. 61 E. CLARK County
 PERMIT NO. 139-18-403-002 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other USA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	0.5	0.5
TYPE II FLU		0.5	1.5	1
SILTY SAND		1.5	3	1.5
CALICHE		3	4	1
SILTY CLAY		4	9	5
CALICHE		9	14	5
SILTY CLAY	20	14	24	10
SILTY CLAY w/GRANITE		24	31.5	7.5

MAP DATUM UGS 84
36° 12.182' N 115° 0' 11.988' W

FACILITY ID #
8-000383

8. WELL CONSTRUCTION
 Depth Drilled 31.5 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/2 Inches To 0 Feet 31.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>5/40 PVC</u>	<u>30</u>	<u>0</u>

Perforations:
 Type perforation MACHINE SCOT
 Size perforation 1.020 10
 From 30 feet to 10 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 8
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 31.5 feet to 8 feet

Date started 7/15, 2008
 Date completed 7/15, 2008

7. WELL TEST DATA

TEST METHOD	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Batter <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	

AUG 4 2008
 LAS VEGAS OFFICE

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EAGLE DRILLING SERVICES LLC Contractor
 Address 7150 PLACID ST. Contractor
LAS VEGAS NV 89119
 Nevada contractor's license number 51266
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 11-2272
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8/01/08