

026811  
 PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33906

1. OWNER W 2007 Arizona Charlits Propco ADDRESS AT WELL LOCATION 740 S. DECATUR BLVD LAS VEGAS NV 89107  
 MAILING ADDRESS 85 BROAD ST NY NY 10004-2434  
 2. LOCATION NE 1/4 SE 1/4 Sec 36 T 20 N/S R 60 E CLARK County  
 PERMIT NO. 138-36-701-022 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other .....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSR

6. LITHOLOGIC LOG

| Material                    | Water Strata | From        | To          | Thickness  |
|-----------------------------|--------------|-------------|-------------|------------|
| <u>SAND &amp; GRAVEL</u>    |              | <u>0</u>    | <u>2</u>    | <u>2</u>   |
| <u>CAILICHI</u>             |              | <u>2</u>    | <u>6</u>    | <u>4</u>   |
| <u>Silty SAND w/ GRAVEL</u> |              | <u>6</u>    | <u>10.5</u> | <u>4.5</u> |
| <u>CAILICHI</u>             |              | <u>10.5</u> | <u>13</u>   | <u>2.5</u> |
| <u>Silty CLAY</u>           |              | <u>13</u>   | <u>15</u>   | <u>2</u>   |
| <u>CAILICHI</u>             |              | <u>15</u>   | <u>16.5</u> | <u>1.5</u> |
| <u>Silty SAND</u>           |              | <u>16.5</u> | <u>25</u>   | <u>8.5</u> |

MAP DATUM  
WGS 84  
36° 09.795' N 115° 12.370' W

FACILITY ID #  
H-000645

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 25  
8 1/2 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2.375</u>       |                     | <u>SC490PK</u>          | <u>25</u>   | <u>0</u>  |

Perforations:  
 Type perforation Machine Set  
 Size perforation 020  
 From 25 feet to 10 feet  
 From ..... feet to ..... feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 8  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 25 feet to 8 feet

Date started 8/03, 2008  
 Date completed 8/03, 2008

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
|        | <u>RECORDED</u>               |              |
|        | <u>AUG 08 2008</u>            |              |
|        | <u>LAS VEGAS OFFICE</u>       |              |

9. WATER LEVEL  
 Static water level 14.5 feet below land surface  
 Artesian flow ..... G.P.M. .... P.S.I.  
 Water temperature WARM °F Quality .....

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FAKE DRILLING SERVICES LLC Contractor  
 Address 7150 PLAZA ST LAS VEGAS NV 89119 Contractor  
 Nevada contractor's license number 51266 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2270  
 Signed Matt J By driller performing actual drilling on site or contractor  
 Date 8/03/08