

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106336
Permit No. _____
Basin 212



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34014

1. OWNER 7/Eleven ADDRESS AT WELL LOCATION 3275 eastern ave
MAILING ADDRESS P.O. Box 711 MN-6 las vegas NV
Dallas Tx 75221-0711 Subdivision Name: _____ County: Clark

2. LOCATION SE 1/4 SE 1/4 Sec 11 T 21N S/W R 61 E Latitude 36 07825 UTM E NAD 27
PERMIT/WAIVER No. 162-11-802-002 Longitude 115 07126 N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Ashpalt		0	3"	#####
coarse gravel		3"	10"	#####
brown fine sand		10"	2	#####
tan silt w/sand		2	10	8
sandy silt	W/L	10	15	5
silty sand w/gravel		15	20	5
tan sand fine		20	25	5

Stamp: DONORSHIP RECEIVED AUG 04 2008 LAS VEGAS OFFICE

9. WELL CONSTRUCTION

Depth Drilled 25 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>25</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.50</u>	<u>10.79</u>	<u>.237</u>	<u>0</u>	<u>24</u>

Perforations:

Type of perforation Factory Slotted
Size of perforation 0.020

From 9 feet to 24 feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No to _____ Pumped Poured
Type: 8/12 Colorado silica

Bentonite Chips: Yes No to _____ Pumped Poured
Type: 3/8 Chips Hydrated

7. Water Level

Static water level: 14 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>bailer</u>		<u>1</u>	<u>.75</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration & Wells
Contractor

Address 570 Corinthian Way
Contractor

Las Vegas, NV 89030

Nevada contractor's license number _____
issued by the State Contractor's Board 0012-852

Nevada driller's license number issued by the
Division of Water Resources, the on-site driller 2057-T-4

Signed _____
By driller performing actual drilling on site or contractor

Date 7-30-08