State 1
Cont 1

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106365
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62008

1. OWNER Keith Kubichek
MAILING ADDRESS 4062 W. WMCA Blvd
WMCA NV 89445

ADDRESS AT WELL LOCATION Junipo Road WMCA
Subdivision Name: No No County: Humboldt

2. LOCATION NW¼ SW ¼ Sec 29 T 36 N/S R 37 E
PERMIT [redacted] 76652
Issued by Water Resources
Parcel No.

Latitude 40.965819
Longitude 117.845526
UTM E 428851 N 4535095
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Hard Pan		5	10	5
Dry Gravel		10	20	10
Rocky Clay		20	40	20
Brown Rocky Clay		40	60	20
Rocky Clay		60	75	15
Brown Rocky Clay		75	95	20
Rocky Clay		95	115	20
Dry Gravel		115	135	20
Rocky Clay		135	155	20
Soft Rocky Clay		155	175	20
Soft Sand Gravel Clay		175	185	10
Soft Sandy Clay		185	195	10
Soft Rocky Clay		195	205	10
Sandy Clay		205	215	10
Hard Rocky Clay		215	225	10
Rocky Clay		225	235	10
Sand & Gravel		235	245	10
Soft Rocky Clay		245	255	10
Rocky Clay		255	260	5

Date started: 7-22 , 20 08
Date completed: 8-1 , 20 08

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 5/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+1	260

Perforations:
Type of perforation Torch Cut.
Size of perforation
From 160 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 55 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 140 to 260 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 55 to 140 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 85 ft feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	130+	Unk	5 Hrs.

STATE ENGINEERS OFFICE
2008 AUG 12 AM 10:23
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC. (Contractor)
Address P.O. BOX 902 - Winnemucca, NV 89446 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed (By driller performing actual drilling on site or contractor) Joe Boggio
Date 8-8-08

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY