WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10368
Permit No.
Basin 044

NOTICE OF INTENT NO. 30539

1. OWNER Wahoo Ranch LLC
MAILING ADDRESS 802 Elberz #11
Elko Nv. 89801
ADDRESS AT WELL LOCATION 12 miles North of Elberz exit 317

2. LOCATION SE ¼ SE ¼ Sec. 2 T. 37 N/S R. 57 E. Elko County
PERMIT NO. 76394 T/76393 76395 Issued by Water Resources | 006-56-0001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Clay, cobble	X	0	34	34
Clay		34	50	16
Sand, gravel	X	50	115	65
Clay		115	180	65
Sand, gravel	X	180	345	165
Clay		345	350	5
Sand, gravel	X	350	390	40
Clay		390	400	10

N 41 7.055
W 115 509 792 NAD27

NAD 27

41° 07.055 N
115° 30.586 W

2008 AUG 22 PM 12:00
STATE ENGINEER'S OFFICE

Date started Jan 3, 2008
Date completed Feb. 10, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150		8 hrs

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	400 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	62.4	.375	+2	400

Perforations:
Type perforation Factory milled
Size perforation 3/16 x 2½
From 120 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 105'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 105 feet to 400 feet

9. WATER LEVEL
Static water level 12.6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Webber Drilling Contractor
Address PO Box 40 Contractor
Overton Nv. 89040
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzabne By driller performing actual drilling on site or contractor
Date Feb. 11, 2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627