

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin. 949
 NOTICE OF INTENT NO. 60132

1. OWNER ANTONIO ORTIZ ADDRESS AT WELL LOCATION LCR
 MAILING ADDRESS _____
SE SW
 2. LOCATION SW 1/4 NE 1/4 Sec 6 T 34 N 1/2 R 56 E ELKO County _____
 PERMIT NO. N/A Issued by Water Resources Parcel No. 032-008-026 Subdivision Name Last Chance Ranch Unit #3

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand clay soil		0	1	1
Clay		1	18	17
Sandy clay		18	21	3
Sand & gravel (cased off)		21	27	6
Blue clay		27	136	109
Shale		136	185	49
Clay, sand, gravel streaks		185	203	18
Shale		203	206	3

4 PS 40.85550 N
 115.21097 W NAD27

8. WELL CONSTRUCTION 206
 Depth Drilled 206 Feet Depth Cased 207 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 Inches 50 Feet 206 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>ASTM F480</u>	<u>.340</u>	<u>26</u>	<u>206</u>
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>1</u>	<u>26</u>

Perforations:
 Type perforation PVC Screen
 Size perforation ?
 From _____ feet to _____ feet
 From 186 feet to 206 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No 40 to 51 Bentonite
 From 51 feet to 206 feet

9. WATER LEVEL
 Static water level 46 feet below land surface
 Artesian flow no G.P.M. _____ P.S.I. _____
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 5-30, 2008
 Date completed 6-11, 2008

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>	<u>50</u>	<u>2 hrs</u>

Name Muth Drilling Co. Contractor
 Address 203 Pine St, Elko, NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 638
 Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date 6-11-08