STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106450
Permit No.
Basin 154

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61351

1. OWNER Barrick Gold
MAILING ADDRESS 293 Spruce Road
Elko, NV 89801

ADDRESS AT WELL LOCATION Cold Springs Ranch, Nework Valley
Subdivision Name:
County: White Pine

2. LOCATION SW ¼ SE ¼ Sec 23 T 23N N/S R 55 E
PERMIT/WAIVER No.
Issued by Water Resources
Parcel No.

Latitude 39.843618
Longitude 115.746166
UTM E 11607275
N 4410943
[x] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	198	198

Date started: 2-Jun, 20 08
Date completed: 6-Jun, 20 08

9. WELL CONSTRUCTION
Depth Drilled 198 Feet Depth Cased 198 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	102	Feet
7 5/8	Inches	102	Feet	198	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.250	+1 1/2	198

Perforations:
Type of perforation: Slotted
Size of perforation: 0.25

From	110	feet to	119	feet
From	121	feet to	126	feet
From	135	feet to	139	feet
From	145	feet to	155	feet
From	170	feet to	180	feet

Annular Seal: [ ] Yes [ ] No

[x] Neat Cement	0 to 102	[x] Pumped	[ ] Poured
[ ] Cement Grout	to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout	to	[ ] Pumped	[ ] Poured
[ ] ≥30% Bentonite Grout	to	[ ] Pumped	[ ] Poured

Gravel Pack: [ ] Yes [x] No to [ ] Pumped [ ] Poured
Type: Driven Well
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 65 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
55 PSI	30	N/A	4 Hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Eklund Drilling Company (Contractor)
Address: PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board*: 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller*: 1777
Signed: Dennis L. White by me (By driller performing actual drilling on site or contractor)
Date: 6/6/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY