STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106471
Permit No.
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60176

1. OWNER JIM SULLIVAN
MAILING ADDRESS P. O. BOX 58
SEDONA, AZ 86339

ADDRESS AT WELL LOCATION 108 BUCKSKIN CIRCLE
LAMOILLE AREA
Subdivision Name: Dysart ~~DYSHART~~ II County: ELKO

2. LOCATION NE ¼ SE ¼ Sec 29 T 33N N/S R 58 E
PERMIT/WAIVER No. 033-002-018
Issued by Water Resources Parcel No.

Latitude 40.713517
Longitude 115.452984
UTM E 11T 0630674 [X] NAD 27
N 4507895 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BRN GRAVEL, SAND & CLAY		2	50	48
BROWN GRAVEL & SAND		50	195	145
HARD BROWN BOULDER	210	195	210	15
COURSE BROWN GRAVEL	215	210	215	5
FINE BROWN GRAVEL	225	215	235	20
COURSE BROWN GRAVEL	XXX	235	255	20

Date started: 8-May, 20 08
Date completed: 9-May, 20 08

9. WELL CONSTRUCTION
Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	255	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	255

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 215 feet to 255 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 20 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 155 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 20 to 50 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 162 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed Jerry C. Bener
By driller performing actual drilling on site or contractor
Date 5/13/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY