


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY

Log No. 106483  
Permit No. \_\_\_\_\_  
Basin 049

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62133

1. OWNER BRAD GREENLAND ADDRESS AT WELL LOCATION 5878 PAIUTE  
MAILING ADDRESS P. O. BOX 1657 OSINO (BLK 11, LOT 1)  
ELKO, NV 89803  
Subdivision Name: Meadow Valley Rancho #3 County: ELKO

2. LOCATION SE 1/4 NW 1/4 Sec 3 T 35N N/S R 56 E Latitude 40.952424 UTM E 11 T 0613469  NAD 27  
PERMIT/WAIVER No. 035-011-001 Longitude 115.651832 N 4534139  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other PLUGGING  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DROVE THE CASING 8" AND BROKE LOOSE ENTERED THE HOLE WITH TREMMIE PIPE TO THE BOTTOM OF THE HOLE AND PUMPED HYDRO GROUT 30 TO THE SURFACE PULLED OUT THE TREMMIE PIPE & PULLED THE CASING TOPPED OFF THE HOLE WITH IN 10' OF THE SURFACE PLACED 2 BAGS OF 1/8" FINE BENTONITE AND USED NEAT CEMENT FROM 20' TO THE SURFACE THE HOLE WAS ABANDONED				
THIS HOLE WAS DRILLED UNDER NOI # 60174 IT HAD NOT BEEN ASSIGNED A STATE WELL LOG # AT THE TIME OF THE PLUGGING ACCORDING TO THE ON LINE WELL LOG SITE				
<i>plugging of log #105644</i>				

9. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
Inches Feet Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
Type of perforation MACHINED MILL SLOT  
Size of perforation  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Annular Seal:  Yes  No  
 Neat Cement to  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout to  Pumped  Poured  
 ≥30% Bentonite Grout to  Pumped  Poured  
Gravel Pack:  Yes  No to  Pumped  Poured  
Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No to  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 11-Apr 20 08  
Date completed: 14-Apr 20 08

7. Water Level  
Static water level: \_\_\_\_\_ feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name HACKWORTH DRILLING, INC.  
Contractor  
Address P. O. BOX 850  
Contractor  
ELKO, NV 89803  
Nevada contractor's license number issued by the State Contractor's Board 020582  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11689  
Signed *David Plum*  
By driller performing actual drilling on site or contractor  
Date 4/14/2008