STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1016504
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61302

1. OWNER Newmont Mining Corporation
MAILING ADDRESS PO Box 669, Carlin, NV 89822

ADDRESS AT WELL LOCATION 4-2 Tailings (North Area)
Hole #MW42-3S
Subdivision Name: County: Eureka

2. LOCATION SE ¼ NW ¼ Sec 3 T 35N N/S R 50 E
PERMIT/WAIVER No. PNV0087065
Issued by Water Resources Parcel No.

Latitude 40°56'34.16"N
Longitude 116°20'46.62"W
UTM E N
[x] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] ~~Test~~
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium (Sand-Clay-Gravel)		0	120	120

N 40.942622
W 116.346283 NAD27

Date started: 24-Feb, 20 08
Date completed: 26-Feb, 20 08

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
15	Inches	0	Feet	19	Feet
8.5	Inches	19	Feet	120	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	21	.188	+1	-19
4		Sch 80	+2.5	115

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 105 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 52 to 0 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 120 to 93 [ ] Pumped [x] Poured
Type: #8 Sand (SRI) 20 - 50# Bags
Bentonite Chips: [x] Yes [ ] No 93 to 52 [ ] Pumped [x] Poured
Type: 3/8" Hole Plug 18 - 50# Bags

7. Water Level
Static water level: 85 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Fair

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1776
Signed Arthur Steelman by (MW) (By driller performing actual drilling on site or contractor)
Date 4/25/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY