STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106505
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61299

1. OWNER Newmont Mining Corporation
MAILING ADDRESS PO Box 669, Carlin, NV 89822

ADDRESS AT WELL LOCATION 4-2 Tailings (North Area)
Hole #MW-42-14S
Subdivision Name: County: Eureka

2. LOCATION ~~SW~~ SE ¼ SW ¼ Sec 32 T 36N N/S R 50 E
PERMIT/WAIVER No. PNV0087065 Issued by Water Resources
Parcel No.

Latitude 40°56'50.12"N
Longitude 116°20'52.97"W
UTM E N
[x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [x] ~~Test~~
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium (sand,Clay, Gravels)		0	100	100

N 40.947256
W 116.348047 NAD27

9. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 95 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
15	Inches	0	Feet	19	Feet
8.5	Inches	19	Feet	100	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	21	.188	+1	-19
4.5		Sch 80	+2.5	95

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 65 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 53 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 100 to 62 [ ] Pumped [x] Poured
Type: #8 Sand (SRI) 23 - 50# Bags
Bentonite Chips: [x] Yes [ ] No 62 to 53 [ ] Pumped [x] Poured
Type: 3/8" Hole Plug 3 - 50# Bags

Date started: 11-Mar 20 08
Date completed: 13-Mar 20 08

7. Water Level
Static water level: 72 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Fair

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1776
Signed Arthur Steelman by [illegible] (By driller performing actual drilling on site or contractor)
Date 4/25/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY