


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61347

1. OWNER General Moly
MAILING ADDRESS 2215 N. 5th Street
Elko, NV 89801

ADDRESS AT WELL LOCATION Mt. Hope
Hole #GMI-PDT3
Subdivision Name: County: Eureka

2. LOCATION NW ¼ SE ¼ Sec 12 T 22N N/S R 5.5 E
PERMIT/WAIVER No. 76803/W-04
Parcel No.

Latitude 39.801323 UTM E 11570921 NAD 27
Longitude 116.171574 N 4405825 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Weathered Quartz Porphyry		0	106	106
Tuff		106	245	139
Hornfeld		245	290	45
Quartz Porphyry		290	825	535
Hornfeld		825	1000	175
Hole was not constructed as a well, casing was not installed, due to unstable hole. Abandonite grout pumped by trimmie from depth to 20'. Bentonite chips coated and kwik plug to form plug next 10' cement to surface.				

9. WELL CONSTRUCTION				
Depth Drilled	1000	Feet	Depth Cased	0
HOLE DIAMETER (BIT SIZE)				
From	To	From	To	
13	0	Feet	810	Feet
12.25	810	Feet	1000	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.25	0	20

Perforations:
Type of perforation 0
Size of perforation 0
From No casing installed feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes No
 Neat Cement 10 to 0 Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured

Gravel Pack: Yes No to Pumped Poured
Type:
Bentonite Chips: Yes No to Pumped Poured
Type: 3/8" kwik plug - 3/8" coated for plug

7. Water Level
Static water level: 246 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cold °F
Quality: Cloudy

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc.
Contractor
Address PO Box 2748
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1819
Signed Gregory Sechrist
By driller performing actual drilling on site or contractor
Date 5/9/2008

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5 Gallon Bucket	133	N/A	2.2 Sec/bucket